

別紙(年度業務報告書関係)

(2) 水質(令和5年度)

②流入水

旧吉野川流域下水道

	気温	水温	透視度	pH	SS	BOD	COD	T-N	NH4-N	NO2-N	NO3-N	T-P	PO4-P	よう素消費量	アルカリ度	大腸菌群数
単位	℃	℃	cm		mg/リットル									mg/リットル	mg/リットル	個/mL
4	16.7	20.4	9.7	7.1	43.3	58.7	42.5	26.5	20.2	0.017	0.975	2.45	1.47	10.8	140	55,000
5	20.0	21.5	9.1	7.1	189.9	141.5	91.5	27.6	20.4	0.020	1.025	2.78	1.86	13.1	132	84,500
6	23.8	22.6	9.9	7.1	50.8	77.9	42.8	23.9	17.7	0.024	1.188	2.43	1.56	10.9	124	77,500
7	28.6	24.3	9.4	7.0	63.4	108.5	47.6	22.8	16.9	0.048	0.976	2.50	1.35	10.6	105	89,000
8	28.6	25.3	9.3	7.0	47.4	83.5	38.5	21.7	13.4	0.090	1.084	2.32	1.27	10.5	125	67,000
9	27.6	25.2	9.3	7.0	86.5	128.9	51.8	21.5	13.2	0.367	1.292	2.69	1.99	8.8	107	69,500
10	21.1	23.8	9.3	7.1	41.6	79.7	44.4	25.9	18.0	0.017	0.946	2.93	1.41	11.0	136	81,500
11	14.4	22.1	10.6	7.2	32.6	53.3	39.5	26.1	19.7	0.019	0.740	2.19	1.50	11.5	120	69,500
12	9.0	20.5	9.1	7.2	70.0	103.8	54.6	25.3	20.5	0.019	0.965	2.39	1.53	12.8	185	61,500
1	6.5	19.2	6.2	7.2	545.5	345.6	166.1	39.4	25.6	0.024	1.111	4.61	2.45	17.7	152	68,000
2	9.3	19.0	5.5	7.2	276.2	259.7	170.8	37.0	21.9	0.125	0.839	4.96	2.86	12.4	130	90,000
3	10.1	18.9	4.6	7.2	159.3	117.4	77.4	35.7	21.2	0.026	0.837	4.93	2.30	9.4	123	70,000
平均	18.0	21.9	8.5	7.1	133.9	129.9	72.3	27.8	19.1	0.066	0.998	3.10	1.80	11.6	132	73,583
最大	28.6	25.3	10.6	7.2	545.5	345.6	170.8	39.4	25.6	0.367	1.292	4.96	2.86	17.7	185	90,000
最小	6.5	18.9	4.6	7.0	32.6	53.3	38.5	21.5	13.2	0.017	0.740	2.19	1.27	8.8	105	55,000