

(2) 水質(令和5年度)

①処理水

旧吉野川流域下水道

	気温	水温	透視度	pH	SS	BOD	COD	T-N	NH4-N	NO2-N	NO3-N	T-P	PO4-P	よう素消費量	アルカリ度	大腸菌群数
単位	℃	℃	cm	—	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	個/mL
(管理目標値)	—	—	—	6.0-8.0	15.0	10.0	13.0	13.00	—	—	—	1.50	—	—	—	1,000
(管理基準値)	—	—	—	5.8-8.6	40.0	15.0	27.0	20.00	—	—	—	1.90	—	—	—	3,000
4	17.0	20.4	78~>100	6.7	4.4	2.4	11.1	11.6	0.900	1.230	6.96	0.44	0.115	3.6	40	3
5	20.4	21.9	88~>100	6.6	1.6	1.4	9.6	10.9	0.608	0.367	6.71	0.40	0.155	3.3	30	11
6	24.0	23.3	>100	6.6	2.0	1.2	8.6	10.6	0.190	0.142	7.94	0.39	0.250	2.3	28	9
7	28.5	25.3	>100	6.6	2.1	1.2	8.5	9.9	0.120	0.079	7.93	0.44	0.275	3.1	30	23
8	28.6	26.2	69~>100	6.7	2.3	1.1	8.9	10.3	0.140	0.059	7.04	0.53	0.395	2.9	30	10
9	27.8	26.0	>100	6.6	1.8	1.1	8.1	10.1	0.170	0.100	5.70	0.58	0.445	2.5	31	8
10	21.3	24.0	>100	6.6	2.3	1.2	8.7	12.3	0.128	0.127	5.86	0.53	0.380	2.8	30	5
11	14.9	21.8	>100	6.6	1.7	1.0	8.4	12.7	0.642	0.180	7.65	0.35	0.235	2.9	30	8
12	9.5	20.0	>100	6.6	2.5	1.7	9.9	12.5	1.593	0.491	7.67	0.34	0.190	2.1	33	4
1	7.0	18.7	70~>100	6.5	3.5	3.0	11.1	15.0	1.928	1.200	11.63	0.35	0.255	2.5	44	2
2	10.0	18.9	90~>100	6.4	3.2	2.1	11.0	14.9	0.598	0.439	10.92	0.35	0.220	1.2	20	3
3	10.5	18.9	>100	6.5	3.5	2.2	11.3	13.1	1.420	0.493	9.20	0.35	0.225	2.5	30	4
平均	18.3	22.1	69~>100	6.6	2.6	1.6	9.6	12.0	0.703	0.409	7.93	0.42	0.262	2.6	31	8
最大	28.6	26.2	>100	6.7	4.4	3.0	11.3	15.0	1.928	1.230	11.63	0.58	0.445	3.6	44	23
最小	7.0	18.7	69	6.4	1.6	1.0	8.1	9.9	0.120	0.059	5.70	0.34	0.115	1.2	20	2