

別紙(年度業務報告書関係)

(2) 水質(令和6年度)

②流入水

旧吉野川流域下水道

	気温	水温	透視度	pH	SS	BOD	COD	T-N	NH4-N	NO2-N	NO3-N	T-P	PO4-P	よう素消費量	アルカリ度	大腸菌群数
単位	℃	℃	cm		mg/リットル									mg/リットル	mg/リットル	個/mL
4	18.3	20.6	6.1	7.0	154.1	170.4	104.4	30.9	21.0	0.042	1.050	5.26	4.75	37.4	136	99,000
5	19.2	21.7	5.8	7.1	130.8	131.9	78.0	30.3	16.5	0.019	0.800	5.16	2.70	22.8	125	54,000
6	23.5	23.1	5.7	7.0	465.8	361.0	185.8	30.4	17.6	0.070	1.250	5.32	2.57	34.9	124	77,500
7	28.7	24.8	5.4	6.9	298.8	121.8	121.6	30.4	16.4	0.022	0.860	6.02	2.81	30.1	125	65,150
8	30.9	26.2	5.4	7.0	427.8	291.8	192.9	29.3	14.5	0.025	1.550	6.86	4.98	24.7	75	42,500
9	29.6	26.3	5.6	7.0	571.9	336.0	200.7	29.9	19.2	0.017	1.450	6.85	4.60	34.7	125	45,000
10	23.6	24.8	5.1	7.1	148.0	143.0	81.9	30.8	18.2	0.014	1.260	5.83	3.47	16.4	136	30,450
11	15.8	22.7	5.1	7.1	381.1	302.1	152.5	32.4	20.2	0.019	1.050	5.46	2.49	12.1	135	56,500
12	9.4	20.6	5.9	7.2	146.4	140.6	75.8	29.4	22.6	0.016	1.000	4.86	2.65	5.3	135	32,500
1	6.4	19.2	6.4	7.2	96.8	102.3	59.2	27.4	21.8	0.016	0.825	4.06	2.75	0.9	121	22,000
2	6.4	18.6	6.7	7.2	100.3	103.5	64.6	26.2	18.8	0.013	0.800	3.74	2.18	7.3	133	20,500
3	12.0	19.2	6.6	7.2	79.4	144.1	52.6	35.0	16.4	0.014	0.475	4.49	2.47	3.4	118	58,000
平均	18.7	22.3	5.8	7.1	250.1	195.7	114.2	30.2	18.6	0.024	1.031	5.33	3.20	19.2	124	50,258
最大	30.9	26.3	6.7	7.2	571.9	361.0	200.7	35.0	22.6	0.070	1.550	6.86	4.98	37.4	136	99,000
最小	6.4	18.6	5.1	6.9	79.4	102.3	52.6	26.2	14.5	0.013	0.475	3.74	2.18	0.9	75	20,500