

別紙(年度業務報告書関係)

(2) 水質(令和6年度)

①処理水

旧吉野川流域下水道

	気温	水温	透視度	pH	SS	BOD	COD	T-N	NH4-N	NO2-N	NO3-N	T-P	PO4-P	よう素消費量	アルカリ度	大腸菌群数
単位	℃	℃	cm	—	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	mg/ℓ	個/mL
(管理目標値)	—	—	—	6.0-8.0	15.0	10.0	13.0	13.00	—	—	—	1.50	—	—	—	1,000
(管理基準値)	—	—	—	5.8-8.6	40.0	15.0	27.0	20.00	—	—	—	1.90	—	—	—	3,000
4	18.1	21.0	>100	6.7	3.3	2.3	11.7	12.9	0.348	0.166	9.70	0.46	0.290	3.8	23	5
5	20.0	22.3	74~>100	6.6	2.6	1.6	9.0	13.3	0.435	0.031	8.63	0.77	0.915	1.9	27	3
6	23.5	23.8	78~>100	6.5	2.4	1.9	9.8	12.4	1.378	0.212	9.63	0.89	0.835	3.3	26	1
7	29.1	25.6	>100	6.6	1.1	1.9	8.6	10.0	1.324	0.340	7.90	0.26	0.050	5.5	40	3
8	31.3	27.0	>100	6.6	0.9	2.5	8.1	9.8	1.193	0.199	8.00	0.27	0.115	3.2	35	1
9	30.4	27.1	>100	6.7	1.2	2.3	9.1	10.4	2.773	0.647	7.50	0.42	0.150	3.2	47	0
10	23.8	25.2	>100	6.6	1.8	2.4	9.0	13.2	3.088	0.773	8.30	0.35	0.155	2.9	68	3
11	16.3	22.7	>100	6.6	2.3	2.4	8.9	14.6	2.520	0.373	11.00	0.33	0.140	2.4	29	3
12	10.3	20.3	>100	6.6	2.1	3.6	9.4	15.9	4.100	0.282	10.25	0.27	0.115	—	34	8
1	7.4	18.8	40~>100	6.5	4.4	2.5	10.7	14.7	1.620	0.389	11.50	0.38	0.230	—	30	4
2	7.1	18.0	>100	6.6	2.0	2.1	10.3	14.6	3.500	0.967	10.00	0.21	0.105	—	37	1
3	12.4	19.0	>100	6.7	2.3	3.7	12.0	16.1	5.930	1.728	10.00	0.32	0.120	1.0	48	2
平均	19.1	22.6	69~>100	6.6	2.2	2.4	9.7	13.2	2.351	0.509	9.37	0.41	0.268	3.0	37	3
最大	31.3	27.1	>100	6.7	4.4	3.7	12.0	16.1	5.930	1.728	11.50	0.89	0.915	5.5	68	8
最小	7.1	18.0	69	6.5	0.9	1.6	8.1	9.8	0.348	0.031	7.50	0.21	0.050	1.0	23	0